

875—92.2(89) Construction criteria.

92.2(1) *Installations from July 1, 1959, to June 30, 1996.* No power boiler shall be installed from July 1, 1959, to June 30, 1996, unless it has been designed, manufactured, inspected, installed, and stamped in accordance with the requirements of ASME Code for Boilers and Pressure Vessels Section I.

92.2(2) *Installations from July 1, 1996, to September 20, 2006.* No power boiler shall be installed from July 1, 1996, to September 20, 2006, unless it has been designed, manufactured, stamped, installed, and inspected to a recognized national or international standard such as ASME, DIN, BSI, JIS, or CSA. Only national and international standards acceptable to the division of labor services may be utilized.